DERBYSHIRE COUNTY COUNCIL MANAGEMENT OF HEALTH & SAFETY AT WORK REGULATIONS CHILDRENS SERVICES



GENERAL HEALTH & SAFETY RISK ASSESSMENT FOR:

Fire Evacuation

PART 1 : ADMINIST	RATIVE DETAILS				_				
Section/Establishm	nent Name: Lea Green Centre					Re	eviews		
					Review	Reviewed by	Date	Changes	Made
Date of Assessmer	nt 16 th October 2023	Date of Issue 1 st November 2023				Y	N		
Assessment	PD	Signature	ure						
carried out by	IW								
								<u> </u>	
Affected persons: Young People/Clients x Staff x Visitors x Contractor X Others (specify)									

Name of Manager confirming and agreeing Assessment:	
Signature:	

The following sections should be completed by all staff who need to be made aware of and abide by the findings of the Risk Assessment. NB: If, as a result of a review, changes are made to the Risk Assessment the relevant box on the attached page should be completed as appropriate by the staff concerned.

RISK ASSESSMENT

What are the hazards?	Generic Control Measures implemented	✓ X	Person to implement	Additional Control measures needed to reduce risk to an acceptable level	Person to implement	Date to be actioned
Discovering a Fire	Raise Alarm - Break Glass - Call emergency Service			Fire Safety Systems Inspections/Testing procedures followed according to DCC guidance of frequency. Quarterly checks on smoke detectors/doors Annual online Fire Safety training to be completed by all staff		
Hearing the Alarm	Muster points for all on site -Tennis Courts -Outside Camp Kitchen Alarm in Duty staff bedroom and manual siren.			 -Assemble at nearest point -Information & directional signage around the house -Twice yearly drill for staff -Residential groups – Drill on first night (any disabled guest sleep on ground floor) -Office Staff or Duty Staff to collect -Staff Sign in/out record -Bedroom List -Visitors sign in /out -Meeting registration -Day groups (Non-residential) – Day register - Roll call to be carried out by senior member of staff. 		
	Departmental roles			 Kitchen – Catering supervisor – turn off isolated power Switches Tennis Courts House – Office & Cleaners – Tennis Courts Development – Tennis Court with Group Or Cottage area with Group Meadow Lodge fitted with sprinkler system – Cottage area. 2nd destination for all groups and staff – Sports Hall and depart by top field gate. 		

Fire Extinguishers/ Blankets	Located on all floors Blanket in kitchen	Annually checked by DCC Staff trained on how to use 5 yearly audit by Derbyshire fire & Rescue	
Real Fire – Lounge & Meeting Room	House hire Groups – to be briefed upon arrival	Only use Lea Green seasoned wood Fire out before last person goes to bed Ashes collected in metal bin once cooled Chimney swept - yearly	
Electrical Items	Use DCC/ Lea Green equipment only	PAT tested and recorded Discourage use of personal items	
Stairs/ Corridors	Kept clear at all times	All staff to move any items	
Smoking/Vaping	None smoking site	Follow DCC guidelines	
Bins & Cardboard	Emptied regular	External bins kept more than 10m from residential building.	
Chemicals/Paint	Kept in designed areas	Locked cupboard or room	
Gas Bottles / Petrol	Kept in lockable container	To be used by competence member of staff. Kept 10m away from the buildings.	